

**NAISMITH ENGINEERING, INC
PROJECT ADDENDUM**

Project Title: Deerhaven W.C.I.D. Water System Improvements – Phase 1	
Owner: Deerhaven W.C.I.D.	
Owner Project No:	NEI Project No: 8566
Addendum Number: One (1)	Date of Issue: 5/14/15
Project Addendum Number One (1) consists of: these <u>2</u> descriptive pages, <u>0</u> pages in the Contract Documents and <u>0</u> plan sheets in the Construction Plans.	
Bid Date & Time: <u>3:00 P.M. Tuesday, May 19, 2015</u>	
NOTICE TO ALL BID DOCUMENT HOLDERS	
The following changes to the Contract Documents are issued by the Design Engineer and shall have the same force and effect as though part of the original issue. Bidders are hereby notified that they shall incorporate this addendum into their bids, and it shall be construed that the contractor's bid shall reflect with full knowledge all items, changes, and modifications to the Contract Documents herein specified. <u>Bidders shall acknowledge receipt of this addendum in the space provided on the bid proposal form, Section 00300 – Bid Proposal.</u>	

CLARIFICATIONS TO THE CONTRACT DOCUMENTS:

1. **Question:** What Texas Water Development Board documents need to be included with the bid?

Answer: In addition to the documents required in Section 00100 "Instruction to Bidders" to be included with the bid, bidders shall also include form TWDB-0459, "Vendor Compliance With Reciprocity on Non-Resident Bidders". This form is included in Section 00903 in the contract documents and specifications.

2. **Question:** Can foreign fittings and/or steel be used for the project?

Answer: Yes. American made fittings and steel are not required in this contract.

3. **Question:** Is there an engineer's estimate for the construction cost?

Answer: Yes. During the planning phase, a construction cost of \$736,324 was estimated for this project (Phase 1).

QUESTIONS AND CLARIFICATIONS TO THE CONSTRUCTION PLANS

1. PLAN SHEETS 4 AND 29

1. Question: What is the intent of the bypass meter vault? Does the meter need to be replaced?

Answer: The intent is to install new bypass piping around the existing meter. The W.C.I.D. currently does not have a bypass around the existing meter. The existing meter is to remain, and the bypass and vault constructed around it.

2. PLAN SHEET 4

1. Question: Is the new pipe between station 0+00 and the bypass meter still part of the project? There was discussion at the pre-bid meeting that it had recently been replaced and would be omitted.

Answer: Yes, that section is still part of the project. The entire proposed 8" new waterline shown on sheet 4 is still part of the project.

ALL OTHER REQUIREMENTS OF THE BIDDING AND CONTRACT DOCUMENTS REMAIN IN EFFECT. THIS ADDENDUM SHALL BE ATTACHED TO AND MADE A PART OF THE BIDDING AND CONTRACT DOCUMENTS. **BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM: SECTION 00300 – BID PROPOSAL.**

Signed & Sealed:



Adam M. Luke, P.E.
Naismith Engineering, Inc.
TBPE Firm Registration No. F-355



Handwritten signature of Adam M. Luke and the date 5/14/15.